

Type Approval Certificate



This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. 13 798 - 99 HH

Company **svt Brandschutz**
Vertriebsgesellschaft mbH International
Glüsinger Straße 86
21217 Seevetal, GERMANY

Product Description **Solvent-free, water based dispersion with inorganic fillers for fire protection of electric cables and cable trays.**

Type **PYRO-SAFE FLAMMOTECT-A**

Environmental Category **None**

Technical Data /
Range of Application **Colour: white or grey**
Density: 1,34 - 1,48 g/cm³
PH-value: Aprox. 7,4
Viscosity: 6.000 - 10.000 mPas

Recommended dry film thickness: 0,5 mm

For spraying and brush-painting application.

FLAMMOTECT-A is mainly used as fire protection coating for the limitation of fire spreading along cable bunches in accordance with SOLAS Consolidated Edition, 1992, Chapter II-1, Regulation 45, 5.2

Test Standard **IEC 60332-3-22, Category A: 2009;**
DIN EN 60332-3-22 / VDE 0482-332-3-22: 2010-08

Documents **Test report : 05/406:2005-09-23; EE/436/98, ENERGOPOMIAR-ELEKTRYKA**
svt Technical Data Sheet PYRO-SAFE FLAMMOTECT-A
svt Application Instruction PYRO-SAFE FLAMMOTECT-A
svt dated 28.10.13

Remarks **Type tests carried out according to IEC 60332-3 cat. A and IEC 60332-3-22 for 60 Minutes**

Valid until **2019-02-12**

Page **1 of 1**

File No. **I.N.06**

Hamburg, 2014-02-12

Type Approval Symbol



Germanischer Lloyd

i.A. [Signature]
Arne Schaarmann

i.A. [Signature]
Carsten Hunsalz